



# UNIVERSITY OF KENTUCKY Purchasing Division

## INVITATION FOR BIDS

CCK-2560-22

AFS Machinery Storage Building

ADDENDUM # 1

07/30/2021

**ATTENTION: This is not an order. Read all instructions, terms and conditions carefully.**

**IMPORTANT: BID AND ADDENDUM MUST BE RECEIVED BY 08/06/2021 @ 3:00 P.M. LEXINGTON, KY TIME**

Bidder must acknowledge receipt of this and any addendum as stated in the Invitation for Bids.

1. Please refer to and incorporate within the offer, the attached written questions and answers.

**OFFICIAL APPROVAL**  
**UNIVERSITY OF KENTUCKY**

**SIGNATURE**

 07/30/2021

Contracting Officer / (859) 257-1024

\_\_\_\_\_  
\_\_\_\_\_

Typed or Printed Name



# UNIVERSITY OF KENTUCKY Purchasing Division

## Written Questions and Answers

CCK-2560-22

AFS Machinery Storage Building

No.	Question	Answer
1.	What is the estimate for this project?	\$70,000
2.	As far as the rock under the shed, what type of gravel do you want to use	6" of compacted DGA over geotextile fabric
3.	As far as the geotextile fabric, what type of fabric Woven or Non-Woven? Also what ounce?	Minimum 10 oz. non-woven fabric
4.	What will be the hours of construction?	Gates are open (free entry) from 6:30am until 6pm on weekdays. Gates are locked daily from 6pm until 6:30am, on weekends, and on holidays. Contractors should not plan to work during non-operating hours, weekends, or on holidays. Special requests may be made to work during non-operating hours but approval cannot be guaranteed.
5.	Is water and electric available?	A yard hydrant is available approximately 50' from the site. A 120V duplex outlet is mounted on the adjacent barn approximately 50' from the site.
6.	What about UK-owned equipment?	Contractor shall provide all equipment necessary to perform tasks. No UK equipment shall be borrowed due to liability issues.