



UNIVERSITY OF KENTUCKY Purchasing Division

INVITATION FOR BIDS

CCK-2666-23

ADDENDUM # 2

11/2/2022

ATTENTION: This is not an order. Read all instructions, terms and conditions carefully.

IMPORTANT: BID AND ADDENDUM MUST BE RECEIVED BY 11/8/2022 @ 3:00 P.M. LEXINGTON, KY TIME

Bidder must acknowledge receipt of this and any addendum as stated in the Invitation for Bids.

1. Please refer to and incorporate within the offer, the attached written questions and answers.

OFFICIAL APPROVAL
UNIVERSITY OF KENTUCKY

Contracting Officer / (859) 257-5792

SIGNATURE

Typed or Printed Name



UNIVERSITY OF KENTUCKY

Purchasing Division

Written Questions and Answers

CCK-2666-23

Slone Building Elevator Modernization

No.	Question	Answer
1.	A floor drain was discovered in the proposed elevator equipment room. What action, if any, needs to be taken? Plugged, capped, left alone, etc.	Section V.B.11 – Plug the existing drain.
2.	The specs call for a WiFi enabled mini-split. Historically, WiFi is not approved by the IT department on campus. Would a BACnet card for the mini-split be a better option?	Section V.B.9.f – Delete WiFi capable. Change to BACnet card for the mini-split.
3.	The new machine room doesn't have a fire rated door. The door frame is also rusted and starting to crumble at the base. Should the new machine room door frame and door be replaced?	New door and frame installed on another project.
4.	The existing 4020 fire alarm control panel and the building is well beyond end of life. I suggest upgrading the 4020 to a 4100 ES. Would it be possible to roll this into this elevator upgrade project?	New fire alarm panel by others. Section I.B.1.t and Section I.B.1.u are still included with this bid.
5.		
6.		