



UNIVERSITY OF KENTUCKY

Purchasing Division

Written Questions and Answers

Security Reader Upgrade

RFP UK-2305-23

Closing Date: 1/6/2023

Today's Date: 12/30/2022

No.	Question	Answer
1	Is it simply removing the old reader and mounting the new one in it's place, and walking on to the next reader? Or is there a commissioning procedure UKPD has in place that must be performed at a replaced reader before moving on to the next one?	Simply removing the reader, mounting the new in its place, walking on to the next reader. Installation and reader communication will be verified by UKPD representative that is escorting the installers.
2	Is a bid bond or performance bond required for this project?	No
3	Will quantities of card reader's with their respective building be made available prior to the proposal to aide in developing an accurate implementation plan?	No. Most are in pavilion A.
4	What date does this project need to be completed by?	Preferably by end of fiscal year (June 30 th) as lead times permit.
5	How soon can work begin on this project?	As soon as contract is awarded UKPD will coordinate with vendor.
6	Will all the readers that need replaced be the same size?	No, there will be readers of two different sizes. Software house readers and old HID readers.
7	If the new reader is bigger or smaller than the reader being replaced, who is responsible for the patch up work if cosmetic improvements are necessary?	The University of Kentucky will be responsible.
8	Who is responsible for touch up paint work if needed?	See above answer to question #7
9	If awarded the project, will we be escorted around to each facility/reader by a UK representative? If not, how will we be given access to perform the work? For example: Will we be given badges and/or a set of drawings that show where the readers are located?	UKPD will provide an escort for all work.

10	If awarded the project, will we be given parking access at each building as we swap out readers? If not, where should we park while performing the work?	Refer to The University of Kentucky Transportation services webpage for all parking information. https://www.uky.edu/transportation/vendor
11	Addendum 1 for this project lists the limit for Cyber Liability as \$5,000,000 each occurrence. Our current limit of \$1,000,000 is standard for our industry and the cost to increase this limit would be substantial. Can the limit for this project be reassessed?	Refer to RFP section 3.5 Proposed Deviations from the RFP. Proposers can identify their coverage level as a deviation from the RFP