



UNIVERSITY OF KENTUCKY Purchasing Division

INVITATION FOR BIDS

CCK-2676-23

ADDENDUM # 1

1/20/2023

ATTENTION: This is not an order. Read all instructions, terms and conditions carefully.

IMPORTANT: BID AND ADDENDUM MUST BE RECEIVED BY 2/1/2023 @ 3:00 P.M. LEXINGTON, KY TIME

Bidder must acknowledge receipt of this and any addendum as stated in the Invitation for Bids.

1. Please refer to and incorporate within the offer, the attached written questions and answers.

OFFICIAL APPROVAL
UNIVERSITY OF KENTUCKY

Patricia Pflug

Contracting Officer / (859) 257-9102

SIGNATURE

Typed or Printed Name



UNIVERSITY OF KENTUCKY
Purchasing Division

Written Questions and Answers

CCK-2676-23

Medical Office Building Re-Keying Good Samaritan Medical Office

No.	Question	Answer
1.	<p>I have a question about this project out for bid. The hardware sets include this line item:</p> <p>1 EA KEY CORE AS INDICATED BY UKHEALTH KEY SHOP</p> <p>Does this mean the UK Key Shop is providing the core or is the Contractor responsible for providing and installing the core? If the Contractor is providing the core, I am assuming it will need to come uncombined and the UK Key Shop will be pinning them in house. Can you confirm/advise? Also, if the Contractor is responsible for providing the core, we will need to know the hardware part number.</p>	<p>Contractor will provide Formatted Key core and cut keys shipped directly to UK Key Shop. UK Key shop will not be pinning cores these will need to be provided pinned. The hardware part is Coremax 7 pin SFIC.</p>