



# UNIVERSITY OF KENTUCKY Purchasing Division

## INVITATION FOR BIDS

CCK-2684-23

HSRB - REPLACE DAMAGED COILS

ADDENDUM# 1

01/20/2023

**ATTENTION: This is not an order. Read all instructions, terms and conditions carefully.**

**IMPORTANT: BID AND ADDENDUM MUST BE RECEIVED BY: 01/27/2023 @ 3:00 P.M. LEXINGTON, KY TIME**

Bidder must acknowledge receipt of this and any addendum as stated in the Invitation for Bids.

**ITEM #1: QUESTIONS AND RESPONSES:**

Refer to and incorporate the attached written questions and responses in your bid.

**ITEM #2: CHANGES TO THE PROJECT MANUAL:**

Disregard the instruction to discard the existing drain pans. They will be reused with the new coils.

END OF ADDENDUM #1

If you have any questions, please contact Ken Scott at the number below or at [cckbidquestions@uky.edu](mailto:cckbidquestions@uky.edu).

**OFFICIAL APPROVAL**  
**UNIVERSITY OF KENTUCKY**

**SIGNATURE**

*Ken Scott*

01/20/2023

Contracting Officer / (859) 257-9102

\_\_\_\_\_

\_\_\_\_\_

Typed or Printed Name

University of Kentucky  
Purchasing Division  
322 Peterson Service Building  
Lexington, KY 40506-0005



# UNIVERSITY OF KENTUCKY

## Purchasing Division

### Written Questions and Answers

CCK-2684-23

HSRB Replace Damaged Coils

1. Where will the owner-provided coils be shipped? **To UK. They will be sitting in front of the AHU's.**
2. Will the owner-provided coils come with the required warranties? **Yes.**
3. Is it your intent to replace all the coils and pipes over one weekend or multiple weekends? **One AHU per weekend.**
4. Please advise if we are to reuse these existing items or provide new ones on the coils. **Yes, you will reuse these valves and strainer.**
  - A. Butterfly Valves
  - B. Control Valves
  - C. Balance Valves
  - D. Wye Strainer
  - E. Thermometers or Air Vents