



# University of Kentucky<sup>®</sup>

*Procurement Services*

REQUEST FOR PROPOSALS

UK-2617.0-8-25

Ag Research Facility 1 – BP-04 Equipment

ADDENDUM # 03

10/01/2024

**ATTENTION: This is not an order. Read all instructions, terms, and conditions carefully.**

**IMPORTANT: RFP AND ADDENDUM MUST BE RECEIVED BY 10/08/2024 @ 3:00 P.M. LEXINGTON, KY TIME**

**Offeror should acknowledge receipt of this, and any addendum as stated in the Request for Proposal.**

**ITEM #1: CLARIFICATIONS AND MODIFICATIONS TO THE BIDDING DOCUMENTS**

Bidders are instructed to review and incorporate into your offer the attached addendum #3 from Turner Construction Company and BHDP Architects.

**OFFICIAL APPROVAL**  
**UNIVERSITY OF KENTUCKY**

Corey W. Leslie, Purchasing Officer

**SIGNATURE**

---

Typed or Printed Name



UK AG Research Building  
TC-025 Mechanical Equipment RFP  
ADDENDUM No. 3  
UK-2617.0-8-25  
09/30/2024

*TCCO Addendum #3 Items*

**Attachments Included:**

- UK-2617.0-8-25 - BHDP Mechanical Equipment RFP - Addendum #3 dated 9/26/2024

---

**Date** 9/26/2024  
**Project Title** University of Kentucky  
Agriculture Research Facility 1  
**To** All Plan Holders  
**Purpose** Modify the Bid Documents  
**Distribution** All Plan Holders  
University of Kentucky  
Turner Construction  
A/E Design Team

---

**TO ALL BIDDERS:** This Addendum modifies the Contract Documents and shall be taken into account in preparing bid proposals and shall become a part of the Contract Documents.

**General:**

Item 1. Bidder Question: *“It does appear that the VFD’s for the units on this bid package are not part of this contract.”*

Response: That is correct, VFD’s will be in a future bid package.

**Drawings:**

Item 2. Sheet M703.1 - MECHANICAL SCHEDULES  
- Add Jetson as an acceptable Manufacturer in the “Dedicated Heat Recovery Chiller Schedule.”

Respectfully Submitted,



Kelly Gardner  
Senior Architect  
BHDP Architecture

**ATTACHMENTS**

1. None

**END OF MECHANICAL EQUIPMENT RFP - ADDENDUM 3**