



# University of Kentucky<sup>®</sup>

Procurement Services

## INVITATION FOR BIDS

CCK-2946.0-1-25

Med Science South Side Replace All Windows

CCK-2946.0

ADDENDUM # 2

1/16/2025

**IMPORTANT: BID AND ADDENDUM MUST BE RECEIVED BY 01-24-2025 @ 3:00 P.M. LEXINGTON, KY TIME**

Bidder must acknowledge receipt of this and any addendum as stated in the Invitation for Bids.

**ITEM #1: Pre-Bid Sign Sheet**

- Pre-Bid Sign In sheet is attached.

**ITEM #2: Questions submitted**

- Answers to the questions due 1/10/25 are attached.

**OFFICIAL APPROVAL**  
**UNIVERSITY OF KENTUCKY**

**SIGNATURE**

*Brian Schwegman*

\_\_\_\_\_

Contracting Officer / (859) 257-9102

\_\_\_\_\_

Typed or Printed Name

**PRE-BID MEETING AGENDA**  
**Med Science South Side Replace All Windows**  
**CCK-2946.0-1-25**  
*Template Updated: November 2024*

Date/Time: 1/8/25  
 Location: UK - Med Science Building

SIGN IN SHEET			
Name	Organization	Phone	E-mail address
1-8-25			
CCK-2946.0-1-25			
MED SCIENCE SOUTH SIDE			
REPLACE ALL WINDOWS			
SIGN-IN			
1. Doug Amshoff	AMHRE SOLUTIONS		
2. Chip Hunter	along amshoff east, com		
3. John Emerson	UK		
4. Brian Sotomayor	UK PURCHASING		
5. Danna Charles	VEI		
6.			
7.			
8.			



## Question and Response Log

Question Deadline 1/10/25

#	Date	From	Question	Responder	Response
1	1/10/2025	Chasteen	1. Once we remove the existing spandrel glass on the first floor windows is there any special/additional work that needs to be done (interior caulk, insulation, etc) to the inaccessible wall/framing due to the interior walls being framed out with no access to the interior/ backside of the windows and framing?	GWW	No. The new insulated panels will cover the existing wall framing the same as the existing spandrel glass
2	1/10/2025	Chasteen	2. Is there any additional exterior caulking (at the gasket area) that needs to be done to the windows due to the air infiltration levels on the storefront assemblies as opposed to the windows that are being replaced especially with the higher elevation and increased wind levels?	GWW	No. Additional caulking should not be required
3	1/10/2025	Chasteen	3. Will temporary safety fencing be required on this job due to it being located at the active loading dock areas?	GWW	Yes
4	1/10/2025	Chasteen	4. Will there be a staging area provided for temporary storage of the new windows/materials etc.?	GWW	Temporary storage may only be staged within the confines of the temporary safety fencing area.