



University of Kentucky[®]

Procurement Services

INVITATION FOR BIDS

CCK-2977.00-1-25

Kroger Field Maintenance 2025

ADDENDUM #2

01/22/2025

IMPORTANT: BID AND ADDENDUM MUST BE RECEIVED BY: 01/30/2025 @ 3:00 P.M. LEXINGTON, KY TIME

Bidder must acknowledge receipt of this and any addendum as stated in the Invitation for Bids.

ITEM #1: QUESTIONS & ANSWERS

- Please refer to and incorporate into your bids the enclosed question(s) and answer(s) from the project team.

OFFICIAL APPROVAL
UNIVERSITY OF KENTUCKY

01/22/2025

Ken Scott

Ken Scott / (859) 257-9102

SIGNATURE

Typed or Printed Name



THP Limited

Addendum No. 2

Date: 1/22/2025

To the Project Manual and Drawings for:

University of Kentucky
2025 Kroger Field Repairs
ITB# CCK-2977.00-1-25
THP #24313.00

Prepared by:

THP Limited Inc.

To:

All Bidders

This addendum supplements and modifies the Project Manual and Drawings for the above Project dated January 2025 and shall hereby be incorporated into the Work as part of the Contract Documents. Bidders shall verify this fact by indicating receipt of the Addendum in their bids.

Contractor Questions:

1. Question 1: Per detail 1/311, 2/311 & 2/321 #13 - Can drains be pumped full of concrete in lieu of saw cutting removing and replacing?
 - a. Answer: No. Bid as noted on plans. Alternative means to remove these drain lines may be considered depending on found conditions in the field during repairs.

Project Manual:

1. N/A

Drawings:

1. N/A

Attachments:

1. N/A

End of Addendum No. 2