

KD-CC-0177-25

## UK King's Daughters Medical Center-Portsmouth, Ohio Humidifier Replacement

ADDENDUM # 02

02/18/25

IMPORTANT: BID AND ADDENDUM MUST BE RECEIVED BY 02/20/2025 @ 3:00 PM EST. OFFEROR MUST ACKNOWLEDGE RECEIPT OF THIS AND ANY ADDENDUM AS STATED IN THE FORM FOR PROPOSAL.

## ITEM #1: UPDATES & REVISIONS TO ORIGINAL BID DOCUMENTS

Please see enclosed additional information from the project team

## **ITEM #2: NOTICES TO BIDDERS:**

 The bid opening has been extended to 02/26/2025. No changes to the time or location for submission of the bids.

**END OF ADDENDUM #02** 

UK KING'S DAUGHTERS MEDICAL CENTER	SIGNATURE
El Beh. Ile	
Ed Belville / Contract Specialist	
	Typed or Print Name



February 17, 2025

King's Daughters Medical Center 2201 Lexington Ave. Ashland, KY 41101

Attn: Mike Layne

RE: KDMC Portsmouth Humidifier – Addendum

Dear: Mike

Please include the following items in the next addendum issued by your office.

## **MECHANICAL**

- 1. Specification section 232213 "Steam and Condensate Heating Piping"
  - a. Steam piping to be schedule 10 stainless steel.

If you have any questions on the above, please feel free to contact me at 330-526-2741 or via email at <a href="mailto:jbilinski@sbmce.com">jbilinski@sbmce.com</a>.

Thank you.

Very truly yours,

Scheeser Buckley Mayfield LLC

Journ Bilinshi

Joseph Bilinski, PE Mechanical Engineer

m:\2024\24209\design\addendum\2025-02-17-jmb-addendum 01.docx