



INVITATION TO BID

KD-CC-0198-26

WOUND CARE RELOCATION

ADDENDUM # 03

11/17/25

IMPORTANT: SIGNED ADDENDUM MUST BE RECEIVED BY 11/19/25 @ 3:00 PM EST. OFFEROR MUST ACKNOWLEDGE RECEIPT OF THIS AND ANY ADDENDUM AS STATED IN THE INFORMATION TO BID.

Item #1: PLEASE NOTE CHANGES

Modification of the project manual and drawings dated September 9, 2025 for the construction of the above listed project.

Clarification of Item 13b.

END OF ADDENDUM 03

OFFICIAL APPROVAL
UK KING'S DAUGHTERS MEDICAL CENTER

A handwritten signature in cursive script, reading 'Becky Pyles', is written over a horizontal line.

Becky Pyles, Purchasing Officer

SIGNATURE

Print Name

Addendum No. 3
Wound Care Relocation
Kings Daughter's Medical Center
Russell, Kentucky

Addendum Issue Date: November 17, 2025

This Addendum is a modification of the Project Manual and Drawings dated September 9, 2025 for the construction of the above listed project. The modifications, revisions, and clarifications are as follows:

Item 1: Clarifications:

- A. Item 13b: ***Hospital-grade MC cable is acceptable in walls and above ceiling for lighting and convenience power circuits. ALL HOMERUNS from first device to panelboard MUST be in EMT.***

Issued by: Zachwieja Workman Architects/Consultants, Inc.