



University of Kentucky®

Procurement Services

INVITATION FOR BIDS

CCK-2979.00-1-26

UK North Farm Seedhouse

ADDENDUM #5

02/05/2026

IMPORTANT: BID AND ADDENDUM MUST BE RECEIVED BY: 02/12/2026 @ 3:00 P.M. LEXINGTON, KY TIME

Bidder must acknowledge receipt of this, and any addendum as stated in the Invitation for Bids.

ITEM #1: UPDATES TO ORIGINAL BID DOCUMENTS

- Please refer to and incorporate into your bid the enclosed additional information from the project team.

ITEM #2: BIDDER NOTICES

- The “Bid Opening” has been extended to 02/12/2026. The time and location for submission of the bids remains the same.
- If you have any questions, feel free to contact Ken Scott at the number below or at Kenneth.Scott@uky.edu.

OFFICIAL APPROVAL
UNIVERSITY OF KENTUCKY

SIGNATURE

02/05/2026

Ken Scott

Ken Scott / (859) 257-9102

Typed or Printed Name

University of Kentucky
Procurement Services
322 Peterson Service Building
Lexington, KY 40506-0005

**UK Project #: 2979.0 Seedhouse****Addendum #5**

Issued: February 5, 2026

BIDDER QUESTIONS

1. None.

ARCHITECTURAL**Plan Sheet Changes:**

2. None.

Specification Changes:

3. None.

MEP**Plan Sheet Changes:**

4. Revised response to bidder question #45: *"In reference to the enclosed circuit breaker fed from the main gear. Connect enclosed circuit breaker to the line side of the main breaker. Provide additional lugs as required. These cables will feed the new enclosed circuit breaker as shown on the documents. The new enclosed circuit breaker shall be service entrance rated. Provide per NEC."*

Attachments:

1. None.

END OF ADDENDUM