



University of Kentucky®

Procurement Services

INVITATION FOR BIDS

CCK-2979.00-1-26

UK North Farm Seedhouse

ADDENDUM #6

02/06/2026

IMPORTANT: BID AND ADDENDUM MUST BE RECEIVED BY: 02/12/2026 @ 3:00 P.M. LEXINGTON, KY TIME

Bidder must acknowledge receipt of this, and any addendum as stated in the Invitation for Bids.

ITEM #1: UPDATES TO ORIGINAL BID DOCUMENTS

- Late Question - Please refer to and incorporate into your bid the enclosed additional information from the project team.
- If you have any questions, feel free to contact Ken Scott at the number below or at Kenneth.Scott@uky.edu.

OFFICIAL APPROVAL
UNIVERSITY OF KENTUCKY

02/06/2026

Ken Scott

Ken Scott / (859) 257-9102

SIGNATURE

Typed or Printed Name

University of Kentucky
Procurement Services
322 Peterson Service Building
Lexington, KY 40506-0005

**UK Project #: 2979.0 Seedhouse****Addendum #5**

Issued: February 6, 2026

BIDDER QUESTIONS

1. *Metal Panels (Roof). The drawings call for this to be patch work, replacing small segments of roof panels shown for demo on AD160. Patch work does not qualify for a 20-year warranty as mentioned in the specs. In order to qualify for the warranty, the full length of the panels would need to be replaced (eave to ridge). This doubles the cost to maintain the 20 yr warranty and creates a very risky proposition for us when bidding.*

A. The Warranty is for the new metal roof over the loading dock. A warranty on the repairs is not included.

ARCHITECTURAL**Plan Sheet Changes:**

2. None.

Specification Changes:

3. None.

MEP**Plan Sheet Changes:**

4. None.

Attachments:

1. None.

END OF ADDENDUM