



University of Kentucky[®]

Procurement Services

INVITATION FOR BIDS

CCK-0088-7-26

UKREC Application Equipment Storage

ADDENDUM # 2

5/6/2026

IMPORTANT: BID AND ADDENDUM MUST BE RECEIVED BY 5/13/2026 @ 3:00 P.M. LEXINGTON, KY TIME

Bidder must acknowledge receipt of this and any addendum as stated in the Invitation for Bids.

ITEM #1: QUESTIONS AND RESPONSES

- Refer to and incorporate within the offer, the enclosed Questions and Responses.

ITEM #2: PRE-BID ATTENDANCE SHEET

- See attached

OFFICIAL APPROVAL
UNIVERSITY OF KENTUCKY

Contracting Officer / (859) 257-9102

SIGNATURE

Typed or Printed Name

#	Date	Question	Response
1	4/20/2026	The electrical plans show fire alarm equipment in the building, and what appears to be a conduit feed from the Existing Crop Protection Building, as if the systems will be tied together. Is all the fire alarm equipment in the New Crop Protection Building supposed to tie to the fire alarm control panel in the Existing Crop building? If so, what is the fire system in the Existing Crop building?	THE OWNER WILL PROVIDE THE FACP, FLOW SWITCHES, HEAT DETECTORS, TEMP SENSORS AND CONNECTION TO EXISTING FIRE ALARM CONTROL PANEL, LOCATED IN CHEMICAL STORAGE BUILDING. THE FACP IS EXISTING (UNDERSTOOD TO BE KIDDE/EDWARDS). THIS CONTRACTOR SHALL PROVIDE ALL NECESSARY CONDUIT, RACEWAY, AND POWER REQUIREMENTS.
2	4/29/2026	Note 3 for gas piping says it should be screwed unless required by code and Note 7 says all indoor piping should be welded. It is only code for concealed pipe to be welded indoors so I am making sure screw is ok for the exposed indoor piping?	FOR 2.5" GAS PIPE SIZE AND SMALLER, IT IS ACCEPTABLE TO USE EXPOSED INDOOR PIPING AS THREADED. ALL 3" AND LARGER INDOOR PIPE SIZE SHALL BE WELDED.
3	4/29/2026	If screwed fittings are allowed, would hydraulic press fittings be allowed?	PRESS FITTINGS ARE NOT ACCEPTABLE
4	4/29/2026	Section 230700 of the specifications requires 2" elastomeric rubber (Armaflex) insulation for the refrigerant piping. Typical and code is 3/4". Is this acceptable?	0.75" THICK ARMAFLEX IS ACCEPTABLE FOR HVAC REFRIGERANT PIPE INSULATION
5	5/1/2026	Specifications call for a 16ga saddle to hang the gas pipe. The typical saddles for 2" and 1" pipe are 18 ga. Is this acceptable or can we not use saddles for the piping that is not insulated?	IT IS ACCEPTABLE TO USE 18 GAUGE SADDLES FOR GAS PIPE 2" AND SMALLER

PRE-BID MEETING AGENDA

CCK-0088-6-26 UKREC Chemical Handling Building

CCK-0088-7-26 UKREC Application Equipment Storage

CCK-0088-8-26 UKREC University Drive Repair and Paving

Template Updated: November 2024

Date/Time:

4/29/2026 @ 10am CST

Location:

University Access Drive, Princeton, KY 42445

SIGN IN SHEET

Name	Organization	Phone	E-mail address
Brandon Leggett	UK	859-257-4401	ble229@uky.edu
David Bjork	Westate Con	270-963-1432	westate@msn.com
Andres F Pool	Westate Const	2708417055	apool@westateconstructor.com
JIM CONNOR	UK	859 261 9253	JIM.CONNOR@UKY.EDU
Chris Garner	Groundworks exc	270-206-0628	groundworksexc@outlook.com
Chels Fostere	Shardo Const	812-480-5028	chels@shardopaving.com
Greg Betts	Murto	270-519-1286	gpbetts@murto.com
Chris Hayden	Murto	270-556-7652	chayden@murto.com
Will Mathis	Sharco Contracting	270-977-6348	WMathis@sharopaving.com
Melanie Morse	Allen Group LLC	270-625-2580	melenam@allen.com
Doug Watts	Madisonville Garage Door	270-821-3667	doug@madisonvillegaragedoors.com
Brian Hooper	UK	859-257-4400	brian.hooper@uky.edu
Jacob McFar	POSSERS GROUP INC	270 348-0340	Jacob.McFar@POSSERSGROUPINC.COM
Cameron Hartig	Mitchell Const	270-983-7244	cameron@myhomesky.com
Bo Smith	Bell Engineering	270-875-5100	Bsmith@hbells.com
AVERY WATKINS	UK AG	859-509-4912	avery.watkins@uky.edu
Brian Schwemmer	UK PROCUREMENT		
Charl Stule	LENOIR		