



Written Questions and Answers

Equipment and Installation Services for IT Hardware Mounts

RFP UK-2629-27

Closing Date: 11/13/2026

Today's Date: 10/28/2026

No.	Question	Answer
1	Would the University share the manufacturers and models of the articulating arms currently installed, so offerors can quote compatible replacement parts for Scenario 6?	GCX & Ergotron are the manufacturers we typically use. For purposes of this question, please assume Ergotron StyleView Sit-Stand Combo Arm w/ Worksurface (white) - part number 45-260-216
2	Are the workstations in Scenarios 1, 2, 3 and 8 dual-monitor, and what monitor size and weight range should offerors assume?	Assume dual for 1 & 2, and single for 3 and 8. Monitor/AIO computer size is 24" standard and weight will be approximately 8lbs-15lbs.
3	For Scenario 4, what display size, weight and Video Electronics Standards Association (VESA) mounting pattern should offerors assume?	Assume 50" size display, up to 45lbs. VESA pattern is 300x300mm up to 400x400mm.
4	For Scenario 5, which camera model and ceiling type should offerors assume?	Assume Axis M5525E camera being mounted in ceiling tile.
5	Does the University have a preferred or standardized mount manufacturer?	The University typically uses GCX and Ergotron for computing devices. Chief are standard for large format displays.
6	Will the University provide wall backing or blocking where mounts are installed?	Yes, where required.
7	Can we copy/paste the labor rate tables after section 7.1 into our response doc, or does UK want us to fill out the tables in the RFP and include the RFP attached to our response?	Both are acceptable
8	Under section 4.6, what information is UK looking for in the blanks of this table? An average response time?	Yes, average times based on the outlined priorities.
9	Will UK have a mock-up room where we can demo some of the new equipment available	Not at this time.

	from manufacturers?	
10	Are we expected to deliver our response in person at UK Lexington, or are we allowed to send the response via courier (FedEx, UPS, et al)?	Either is acceptable. See section 3.6.
11	Does UK want their wall-mounted articulating arms to be white? Should we add both colors to the response just to be sure?	Assume white only.